

PERFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION
CERTIFICATE

Ref. No. 1124

Date: 09/04/2026

It is certified that an inspection team headed by Dijeta Kumari (Junior Engineer) (Name of officers with designation) from P.H.Division, Nawada PHED inspected the **Modern English School, Nawada., Nawada. Near Kunti Nagar, Nawada (Bihar) Distt.- Nawada.** (Name and address of the school) on 09/03/2026 (Date of inspection) and on the basis of Water Test Report (Attached) report no DLWTL/NWD/ 3220. Dated - 09/04/26 of District Level Water Testing Laboratory (PHED Lab) certified that the **Modern English School, Nawada..** (Name Of School) has safe drinking water facilities for the students and members of staff of the institution. School is also maintain the hygienic sanitation condition in the school building & campus as per norms prescribe by the central/state/U.T. Govt.

This certificate is valid till Six months (As per date of issue).

Signature with Seal:

Name- Sajeet Kumar:

Designation: Executive Engineer

Name & Address of the P. H. Division Nawada

09.04.2026

Office/Department:

To,

The **Modern English School, Nawada., Nawada. Near Kunti Nagar New Area-2, Nawada (Bihar) Distt.- Nawada. Pin- 805110**

(Name & Address of the Institution)

Note: The certificate is to be issued by authorized officer/PHED Lab/local bodies

Government of Bihar Public Health Engineering Department Water Quality Report

District:- Nawada

Division Name:- Public Health Engineering Division, Nawada

Sample Code:- DLWTL/NWD/3220

Sample Collected by:- Modern English School, Nawada. (J.E. Dijeta Kumari)

Date of Sampling :- 24-02-2026

Sample Collected by: Modern English School, Nawada. (J.E. Dijeta Kumar)					Date of Sampling :- 24-02-2026													
Sl. NO	Block	Nagar Parishad	Village	Scheme	Test Report												Source of water	Remarks
					pH	Turb.	EC	TDS	TH	Ca	Mg	Cl	ALK	F				
1	2	3	4	6	7	8	9	10	11	12	13	14	15	16	17	18		
1	Nawada	Nawada	Kunti Nagar new area-2	Tubewell	7.25	0.58	650	423	211	63	14	67	207	0.34	Tap Water			
Desirable Limit* (IS10500:2012)					6.5	1.0	500	500	200	75	30	250	200	1.0				
Permissible Limit* in absence of alternate source					8.5	5.0	2000	2000	600	200	100	1000	600	1.5				

P.H. Division, Nawada

Chemist
04.04.2026

P.H. Sub. Division, Nawada

Assistant Engineer

P.H. Division, Nawada

Executive Engineer